



Line – Near Misses

On 5-2-18:

Line & Tool Room tested a Klein 477-954 Grip w/ Dynamometer, pulling 2500lbs strength. Actual grip was used with the same type of wire that crew was pulling.

During the test the grip slipped immediately and no load was measured on dyno. Another Klein 477 grip was placed on wire and it pulled up load with no slip.




Line – Near Misses

Upon further inspection a small burr was discovered on the slide of the grip. This burr would catch and prevent the grip slide from functioning to tighten on the line.



Burr on Slide

Blue Arrows
Showing Burr and catch area on grip



Line – Near Misses

Larger View

Showing Burr and Slide

Note the Size of Burr



**Feedback from manufacturer
on condition:**

**Crews to inspect Slide before
use for units in service, return
to Tool Room if found
Tool Room to inspect
inventory for this condition
Klein Rep coming May 21st to
review.**